



NOTES:

1. THIS DETAIL SHALL BE USED AT ALL TRANSITIONS BETWEEN PVC PIPE AND DUCTILE IRON PIPE.
2. TRANSITIONS SHALL BE LOCATED OUTSIDE OF RESTRAINED AREAS, UNLESS APPROVED BY OVWC.
3. TRANSITIONS LOCATED WITHIN RESTRAINED AREAS SHALL BE RESTRAINED. RESTRAINING DEVICE FOR THE PVC PIPE SIDE SHALL BE EBAA 2000PV OR STAR PIPE PRODUCTS ALLGRIP 3600. RESTRAINING DEVICE FOR THE DUCTILE IRON PIPE SIDE SHALL BE EBAA MEGALUG 1100, STAR PIPE PRODUCTS STARGRIP 3000, OR SIGMA ONE LOK SLD.
4. RESTRAINING DEVICES NOT REQUIRED IF TRANSITION IS NOT IN A RESTRAINED AREA.
5. ALL BURIED METAL SHALL BE ENCASED WITH 8 MIL POLYETHYLENE SO THAT NO SOIL IS IN CONTACT WITH METAL.

ORANGE VALE WATER COMPANY



TRANSITION SLEEVE

SCALE: NONE
DATE: 05/12

OV-8